

DATE SUBMITTED 03/08/2023
 SUBMITTED BY Public Services
 DATE ACTION REQUIRED 03/15/2023

COUNCIL ACTION
 PUBLIC HEARING REQUIRED
 RESOLUTION
 ORDINANCE 1ST READING
 ORDINANCE 2ND READING
 CITY CLERK'S INITIALS AB

IMPERIAL CITY COUNCIL AGENDA ITEM

SUBJECT: Continue Emergency of Sink Hole at Anthony Redondo Memorial Park	DISCUSSION/ACTION: I. Continue Emergency Action of Resolution No. 2023-06
DEPARTMENT INVOLVED: Public Services and Parks Department	
BACKGROUND/SUMMARY: On Monday, January 30 th , Public Services responded to a reported sinkhole near a storm drain diverter box at the Sky Ranch Park (Boley Field and Sandalwood Glenn). The Parks department had confirmed they had filled it twice before. Upon inspection, the sinkhole seemed to be 4' in depth and 5' in diameter. Upon further investigation, the sink hole has measured to 14' in depth and 8' in diameter. The surrounding banks have and continued to cave in causing a public safety issue. Public Services has since blocked oil the area and has determined the cause to be a result of collapsing lines in the City's storm drain system, in that area. We are currently working with A&R Construction to resolve and make needed repairs to correct the issue.	
FISCAL IMPACT: Unknown at this time	FINANCE INITIALS <u>DG</u>
STAFF RECOMMENDATION: Approve to Continue	DEPT. INITIALS <u>[Signature]</u>
MANAGER'S RECOMMENDATION: <i>Approve continuation of emergency</i>	CITY MANAGER'S INITIALS <u>Oxton</u>
MOTION: SECONDED: APPROVED <input type="checkbox"/> REJECTED <input type="checkbox"/> AYES: DISAPPROVED <input type="checkbox"/> DEFERRED <input type="checkbox"/> NAYES: ABSENT: REFERRED TO:	