

DATE SUBMITTED 11/24/2020
 SUBMITTED BY Public Services
 DATE ACTION REQUIRED 12/02/2020

COUNCIL ACTION
 PUBLIC HEARING REQUIRED
 RESOLUTION
 ORDINANCE 1ST READING
 ORDINANCE 2ND READING
 CITY CLERK'S INITIALS *ob*

**IMPERIAL CITY COUNCIL
 AGENDA ITEM**

SUBJECT: Continue Emergency Filter Piping	DISCUSSION/ACTION: Declare Emergency at Water Treatment Plant Piping Gallery. 1. Continue Resolution NO. 2020-60, Emergency Filter Gallery Piping.
DEPARTMENT INVOLVED: <u>Public Services</u>	
BACKGROUND/SUMMARY: On Monday, November 2 nd , it was discovered that the piping in the filter piping gallery running through the cement floor, has deteriorated to a point that is critical in making repairs or replacement, as soon as possible. This piping was installed under construction between 1993 & 1995 when the Water Plant was placed into operation. There are four (4) 18" steel pipes in question. These 4 pipes connect to a common header without any valves for control. A failure at any one or all, will prevent the Water Treatment Plant from producing potable water. If this occurs, this could result in health and safety issues from the City not being able to produce water. After further review with City Manager and Assistant Manager, emergency action was declared. Public Services is currently working with Webb & Associates to establish corrective measure. Emergency Action & Resolution approved by council on 11/04/2020 At this time cost and time frame to complete are unknown.	
FISCAL IMPACT: Unknown	FINANCE INITIALS _____
STAFF RECOMMENDATION: Council continues emergency	DEPT. INITIALS <i>PS</i>
MANAGER'S RECOMMENDATION:	CITY MANAGER'S INITIALS _____
MOTION: SECONDED: APPROVED <input type="checkbox"/> REJECTED <input type="checkbox"/> AYES: DISAPPROVED <input type="checkbox"/> DEFERRED <input type="checkbox"/> NAYES: ABSENT: REFERRED TO:	