

DATE SUBMITTED 12/14/2022  
 SUBMITTED BY Public Services  
 DATE ACTION REQUIRED 12/21/2022

COUNCIL ACTION ( )  
 PUBLIC HEARING REQUIRED ( )  
 RESOLUTION ( )  
 ORDINANCE 1<sup>ST</sup> READING ( )  
 ORDINANCE 2<sup>ND</sup> READING ( )  
 CITY CLERK'S INITIALS ( )

**IMPERIAL CITY COUNCIL  
 AGENDA ITEM**

SUBJECT: <b>DISCUSSION/ACTION: Declare Emergency at Hwy 86 &amp; Aten Rd.</b> Continue Emergency Lift Stations                      1. Continue Emergency Action of Resolution NO. 2022-60	
DEPARTMENT INVOLVED:      Public Services – Waste Water	
BACKGROUND/SUMMARY:  After replacing suction lines at three lift stations back in mid- June, Public Services inspected other pump & lift stations and found four other stations needing suction lines removed and replaced. Bracing and supports for these suctions line have also failed and will be replaced, as well. This is critical and considered an emergency repair to continuing to provide sewer collection in the areas of: Sandalwood Glen, Sky Ranch, Cross & Colonia Pump/Lift Stations. If lines continue to fail, these lift stations will not be able to function; each one currently has a failed line and are running at 50%.  Public Services is continuing to work with A&R Construction to rectify issues.	
FISCAL IMPACT: TBD	FINANCE INITIALS <u>DP</u>
STAFF RECOMMENDATION: Council continues approval of emergency action	DEPT. INITIALS <u>[Signature]</u>
MANAGER'S RECOMMENDATION: <u>approve</u>	CITY MANAGER'S INITIALS <u>[Signature]</u>
MOTION:   SECONDED:                      APPROVED ( )                      REJECTED ( ) AYES:                              DISAPPROVED ( )                      DEFERRED ( ) NAYES: ABSENT:                              REFERRED TO:	