## CITY OF IMPERIAL

## "7th ST REHABILITATION & PEDESTRIAN IMPROVEMENTS FROM SOUTH "D" STREET TO SOUTH "E" STREET" Bid No. 2024-04 {LPP-SB1 5134(029)}

## ADDENDUM No. 1

06/18/2024

TO THE CONTRACT DOCUMENTS AND SPECIFICATIONS.

## NOTICE TO ALL POTENTIAL RESPONDENTS

The Bid Documents and Specifications are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents and Specifications. Respondent shall take this Addendum into consideration when preparing and submitting its Proposal.

Bidders are advised that the contract documents and specifications for the above referenced contract are hereby amended in the following manner and the following manner only:

This Addendum answers bidder's questions:

1. The overall design to place 4" of Gap Graded RHMA over the pulverized roadway. Would the City of Imperial consider a 2.5" Base Course of 3/4" Type A HMA for a base course with 1.5" finish of 1/2" GG RHMA to equal the 4" paving section as that is a lot of RHMA for a roadway section? Please advise?

YES, the revised asphalt cross-section should be as follows:

2" Base Course of  $\frac{3}{4}$ " Type A HMA for a base course with 2" finish of  $\frac{1}{2}$ " Asphalt-Rubber Hot Mix Gap-Graded (ARHM- GG) to equal 4" paving section.

2. Is there an engineer's estimate for this project for bonding purposes? Please advise

YES, the Opinion of Probable Construction Cost (OPCC) is \$273,600.

3. Is this an Engineer's Estimate on this project?

YES, the Opinion of Probable Construction Cost (OPCC) is \$273,600.

Please acknowledge receipt of this addendum by signing and returning a copy of the Acceptance of Notice via email to jvillegas@cityofimperial.org. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Sheet Proposal.

Contractor's responsibility to notify its sub-contractors about changes based all addendums.

By: Othon Mora
Community Development Director

ACCEPTANCE OF NOTICE
Receipt of the ADDENDUM No. 1 is hereby acknowledged by

Bidder's Company Name

Type or Print Name & Signature

Include a copy of this addendum with your Bid Proposal Package. It is the

Title